



**FOOD PREMISES INSPECTION REPORT
for Non-Compliant
Critical / Non-Critical Items
Date of Report - February 05, 2025**

**Grand Falls-Windsor Long Term Care
9 Scott Avenue, Grand Falls-Windsor, NL**

Yearly Operation

For additional information on the Inspection process, please see:

http://www.servicenl.gov.nl.ca/inspections/inspection_information.pdf

Inspection Type and Date	Compliance Item Type	Code - Description	Observations and Corrective Actions
Food - Annual Inspection Jan 29, 2025		Compliant at the time of this inspection	
Food - Complaint/Demand Insp. Oct 29, 2024	Non-Critical Item(s)	702 - Non-food contact surfaces properly constructed, in good repair and clean	Steam kettle floor drain (under hood vent) not draining properly, please correct.
		704 - Adequate protection from vermin and insect pests	extra door sweeps required on dry storage room(bottom of door), double pedestrian exit to outside near loading bays, and double door from loading area to staff back hall. Lifts in floor require better seals recommend extra pest control prevention (ie lights) installed (currently working on obtaining these)
Food - Routine Inspection Aug 19, 2024		Compliant at the time of this inspection	
Food - Annual Inspection Jan 29, 2024		Compliant at the time of this inspection	
Food - Routine Inspection Sep 28, 2023		Compliant at the time of this inspection	



**FOOD PREMISES INSPECTION REPORT
for Non-Compliant
Critical / Non-Critical Items
Date of Report - February 05, 2025**

**Grand Falls-Windsor Long Term Care
9 Scott Avenue, Grand Falls-Windsor, NL**

Yearly Operation

For additional information on the Inspection process, please see:

http://www.servicenl.gov.nl.ca/inspections/inspection_information.pdf

Inspection Type and Date	Compliance Item		Observations and Corrective Actions
	Type	Code - Description	
Food - Routine Inspection Jun 19, 2023	Non-Critical Item(s)	702 - Non-food contact surfaces properly constructed, in good repair and clean	when sink is drained it overflows up through floor drain - causing possible contamination due to food particles and standing water/suds on floor. Please have corrected.
Food - Routine Inspection Mar 13, 2023	Critical Item(s)	401 - Food Separated and Protected	ice machine - storage must be inaccessible to non-staff.
	Non-Critical Item(s)	702 - Non-food contact surfaces properly constructed, in good repair and clean	backsplash behind dishwasher inadequate. Requires taller backsplash (non-absorbent and easy to clean) as food particles are splashing on brick